

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED HINDS		PERMIT NUMBER
WELL NUMBER J-201	CODED	NAME OF DRILLING FIRM EMBED CRESSWELL
DATE WELL COMPLETED MAY 23 2001		BENTON, MS. 39040

NAME & MAILING ADDRESS OF LANDOWNER
CRIS WISECARVER
4016 WHEAT DRIVE
METAIRIE, LA - 70002

WELL LOCATION	SEC	TOWNSHIP	RANGE
	22	15 N	5 E
DISTANCE	DIRECTION	NEAREST TOWN	
2 Miles	North	NEWMAN	

OTHER LANDMARK

WELL PURPOSE: Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) **H/P**

Pump Capacity (GPM)	No. of Stages	Setting Depth
12	12	189 FT.

PUMP TEST
Well yielded **15** GPM with a drawdown of **30** ft. after **2** hours of pumping

WELL DATA

Well Depth 245	Casing Diameter (In.) 4	Casing Length (Ft.) 225
Type of Casing PVC	Hole Depth 260	Depth to Static Water Level 85

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other

WELL GROUTED TO A DEPTH OF **25** FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run,
 Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches 4	Length - Feet 20	Slot Size - Inches .010
Screen Type PVC	Depth to Bottom - Feet 245	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
SURFACE DEPOSITS	0	30			
GRAY SHALE	30	85			
SAND	85	163			
SHALE	163	173			
UB LIMESTONE	173	225			
MINT SPRINGS	225	245			
SHALE	245	260			

REC'D MAY 30 2001

IF MORE SPACE IS NEEDED USE BACK