

HINDS
 N76
 7-20-70

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

7-20 1970 James D McNEES Hinds
 date well completed firm name county well located

| LANDOWNER | description of formations encountered | from | to |
|---|---------------------------------------|------|-----|
| ASPHALT PAVING CO JACKSON MISS | clay | 0 | 20 |
| | Blue shale | 20 | 190 |
| | sandy sh | 190 | 220 |
| (mailing address) | | 220 | 448 |
| | Rock | 448 | 449 |
| WELL LOCATION: sec 21 T 5 N R 1 E | SAND-sh STKS | 449 | 630 |
| 1/4 miles south of JACKSON | SAND | 530 | 690 |
| (distance) (direction) (nearest town) | SAND-sh STKS | 690 | 720 |
| WELL PURPOSE: Industrial (home, irrigation, municipal, industrial) | SAND | 720 | 860 |
| | Grey sh | 860 | 873 |
| WELL COMPLETION DATA: | | | |
| (1) diameter (inches) 4" x 2 1/2" | 19 fts - 4" | 401 | 5 |
| (2) total depth (feet) 873 | 4" x 2 1/2" swedge | 1 | |
| (3) static water level (feet) 177 below top of ground. | 19 fts 2 1/2" | 402 | 5 |
| (4) casing steel 803 (material) (depth) | | 401 | 1 |
| (size) If telescope see back. | 30' 2 1/2 stainless | 803 | 6 |
| (5) screen 30' 803 - 11 (length) (depth to top) | steel screen | 30 | |
| 2 1/2 stainless steel (size) (material) | | 833 | 7 |
| (6) pump 5 60 (HP) (yield gpm) | | | |
| Elec (type power) | | | |
| (7) electric log yes (yes or no) | | | |
| M.G.S (organization running log) | | | |
| (8) how well bottom plugged mud | | | |
| DRILLERS REMARKS: NO COLOR | | | |

SEP 7 1970

MISS. BD. OF
 WATER COMM.

If well telescopes please
sketch and show depths.

GROUND LEVEL

| | | | |
|--|--|--|--|
| | | | |
| | | | |
| | | | |
| | | | |

SECTION _____

Please indicate well location X.

ADDITIONAL INFORMATION

If more than one screen,
show locations of each on sketch.