

HINDS
P71
7-28-77
E log #613

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

CODED

7/28 1977 Terrell Geom Water Well Ser. Hinds
date well completed firm name county well located

LANDOWNER: Mr. Terrell
LARRY R. TERRELL
Lebanon + Pine Grove Rd.
Leavel, Ms.
(mailing address)

description of formations encountered	from	to
Clay	0	220
Rock	220	260
Sand	260	324

WELL LOCATION:
sec. 23T 4N R. 3W
7 miles S of Raymond
(distance) (direction) (nearest town)

WELL PURPOSE: Home
(home, irrigation, municipal, industrial)

CODED

- WELL COMPLETION DATA:
- (1) diameter (inches) 4
 - (2) total depth (feet) 324
 - (3) static water level (feet) 84' below top of ground.
 - (4) casing PVC 270'
(material) (depth)
4" if telescope see back.
(size)
 - (5) screen 30' 300'
(length) (depth to top)
4" PVC
(size) (material)
 - (6) pump 3/4 10
(HP) (yield gpm)
electricity
(type power)
 - (7) electric log Yes
(yes or no)
Ms. Geological Survey
(organization running log)
 - (8) how well bottom plugged

RECEIVED
AUG 31 1977

DRILLERS REMARKS: