

ALREADY LOGGED

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED HINDS	
WELL NUMBER 330481	CODED <input checked="" type="checkbox"/>
R180	
DATE WELL COMPLETED 2-13-93	

PERMIT NUMBER 510
NAME OF DRILLING FIRM Easley Water Well
Brookhaven MS 39601

NAME & MAILING ADDRESS OF LANDOWNER Mr. Gardner		
WELL LOCATION: SEC 19 TOWNSHIP 4 RANGE 1 <input checked="" type="checkbox"/> W <input checked="" type="checkbox"/> S		
DISTANCE _____ Miles	DIRECTION _____	NEAREST TOWN _____
OTHER LANDMARK _____		
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.		

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____		
Pump Capacity (GPM)	No. of Stages	Setting Depth _____ FT.
PUMP TEST		
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth 125'	Casing Diameter (In.) 4"	Casing Length (Ft.) 115'
Type of Casing PVC	Hole Depth 140'	Depth to Static Water Level _____
TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) HOME		
Top of Lap Pipe or Reduction in Casing FEET _____ IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE		

LOG DATA	
TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____	
Name of Organization Running Log _____	

SCREEN DATA		
Diameter - Inches 4"	Length - Feet 20'	Slot Size - Inches #8
Screen Type PVC	Depth to Bottom - Feet 140'	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
CLAY	0	20			
SAND	20	50			
ROCK	50	100			
SAND	100	125			
CLAY	125	140			

IF MORE SPACE IS NEEDED, USE BACK