

Keedtown Test well +

1190

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
 Office of Land and Water Resources
 P. O. Box 2309
 Jackson, MS 39225
 Water Well Plugging/Decommissioning Form
 OLWR-DF-1 (04/08)

RECEIVED
 MAY 30 2017
 BY OLWR

COUNTY WELL LOCATED: <u>Hinds</u>		WELL NUMBER: <u>S65</u>	
PERMIT NUMBER:		DATE WELL PLUGGED: <u>5-2-17</u>	
NAME OF FIRM PLUGGING WELL: <u>Thompson Bros.</u>		TELEPHONE NUMBER:	
NAME AND ADDRESS OF CURRENT LANDOWNER: <u>Keedtown Water Assoc.</u>			
WELL LOCATION:		SECTION: <u>31</u>	TOWNSHIP: <u>3N</u> RANGE: <u>4W</u>
WELL LOCATION: LATITUDE: <u>32°03'51.3"</u> LONGITUDE: <u>90°38'21.8"</u>		METHOD (CIRCLE ONE): (1) USGS QUAD (2) CONVENTIONAL SURVEY (3) GPS - HAND HELD OR SURVEY GRADE	
DISTANCE: <u>2.5</u> DIRECTION: <u>S</u>		NEAREST TOWN: <u>Utica</u> OTHER LANDMARK:	
WELL PURPOSE (HOME, IRRIGATION, MUNICIPAL, ETC.): <u>test well</u>			
NAME OF WELL CONTRACTOR WHO DRILLED THE WELL: <u>Thompson Brothers</u>			
NAME OF LANDOWNER WHEN WELL WAS DRILLED: <u>Keedtown Water Assoc.</u>			

WELL DATA			
WELL DEPTH: <u>360</u>		HOLE DEPTH: <u>400</u>	
CASING DIAMETER (IN.): <u>4</u>	CASING LENGTH (FT.): <u>320</u>	TYPE OF CASING: <u>PVC</u>	
DEPTH TO STATIC WATER LEVEL: <u>64</u>		DATE WELL COMPLETED: <u>5-2-17</u>	
WHY IS THE WELL BEING ABANDONED? <u>Finished test</u>			

DESCRIBE HOW THE WELL OR HOLE WAS PLUGGED (AMOUNT OF CASING AND/OR SCREEN THAT WAS REMOVED OR LEFT IN HOLE, MATERIAL AND AMOUNT USED IN PLUGGING, METHOD OF PLACING MATERIAL, ETC.)

Pumped cement to bottom of well up to 180' so that upper sand from 160-180 could be tested next.

I CERTIFY THAT THE WELL WAS PLUGGED OR ABANDONED IN ACCORDANCE WITH THE STATE OF MISSISSIPPI REGULATIONS.

<u>John Thompson</u>	<u>0-679</u>
<small>AGENT NAME</small>	<small>MS LICENSE NUMBER</small>
<u>John W. Thompson</u>	<u>5-30-17</u>
<small>SIGNATURE</small>	<small>DATE</small>