

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Holmes

WELL NUMBER CODED
B 2016

PERMIT NUMBER

NAME OF DRILLING FIRM
IRRIGATION EQUIPMENT

DATE WELL COMPLETED
5-5-99

601/887-2555
INDIANOLA, MS

NAME & MAILING ADDRESS OF LANDOWNER

Killebrew Farms

Rt. 2, Box 391

Lexington, MS 39095

WELL LOCATION SEC TOWNSHIP RANGE

26 17 N 1 E

DISTANCE DIRECTION NEAREST TOWN

3 Miles SE of Cruger

OTHER LANDMARK

WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

Irrigation

WELL DATA

Well Depth Casing Diameter (In.) Casing Length (Ft.)
117 16 77

Type of Casing Hole Depth Depth to Static Water Level
PVC 117

TYPE OF COMPLETION: (Circle One or More):
 Gravel Pack, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF FEET

Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches Length - Feet Slot Size - Inches
16 40 .050

Screen Type Depth to Bottom - Feet
PVC 117

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
CLAY	0	35
FINE SAND	35	45
FINE SAND + GRAVEL	45	70
med. SAND + GRAVEL	70	117

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P **60**

Pump Capacity (GPM) No. of Stages Setting Depth
1 60 FT.

PUMP TEST
Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) No Log Run,

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

RECEIVED

SEP 01 1999

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK