

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Holmes

WELL NUMBER: #1 CODED

PERMIT NUMBER

M 2002

NAME OF DRILLING FIRM*
Arnold Fincher Sr

DATE WELL COMPLETED
12-5-94

Brandon, MS

NAME & MAILING ADDRESS OF LANDOWNER

Henry B. McClellan
P.O. Box 399

Goodman, MS 39079

WELL LOCATION SEC TOWNSHIP RANGE
25 15 N 3 E

DISTANCE DIRECTION NEAREST TOWN
5 Miles West of Durant

OTHER LANDMARK

WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA

PUMP TYPE (Circle One):
Submersible Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P 1/2

Pump Capacity (GPM) No. of Stages Setting Depth
10 8 85 FT.

PUMP TEST
Well yielded 10 GPM with
a drawdown of 10 ft.
after 4 hours of pumping

WELL DATA

Well Depth Casing Diameter (In.) Casing Length (Ft.)
90 4 80

Type of Casing Hole Depth Depth to Static Water Level
PVC 90 65 ft

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches Length - Feet Slot Size - Inches
4 10 .10

Screen Type Depth to Bottom - Feet
PVC 90

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, No Log Run,
Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>Top Soil</u>	<u>0</u>	<u>2</u>			
<u>Sand</u>	<u>2</u>	<u>90</u>			

RECEIVED

DEC 06 1994

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK