

15K

CODED

CODED

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

Holmes
T 25
12-10-68
M.G.S.
12-10- 1968

Super Central Co. firm name
Holmes county well located

LANDOWNER:	description of formations encountered	from	to
City of Durant			
Durant, Miss (mailing address)	Clay	0	18
	Sand	18	63
	Blue Clay	63	91
	Sand	91	103
WELL LOCATION: NW 3E 3E	Clay	103	124
sec. 11 T 14 R 4	Sandy Clay	124	133
One Block West of Hwy 51	Sand	133	155
(distance) (direction) of (nearest town)	Sand	155	181
WELL PURPOSE: Municipal	Hard Shale	181	199
(home, irrigation, municipal, industrial)	Hard Sandy Shale	199	226
WELL COMPLETION DATA:	Rock	226	228
(1) diameter (inches) 18"	Hard Shale	228	262
(2) total depth (feet) 672'	Rocky Medium Hard	262	263
(3) static water level (feet) Flow below top of ground.	Hard Sandy Shale	263	269
(4) casing Steel 610' (material) (depth)	Peaked Sand	269	275
18" (size) if telescope see back.	Hard Sandy Shale	275	289
(5) screen 50' 610' (length) (depth to top)	Sand, Hard Salt + Lippa	289	312
10" stainless steel (size) (material)	Hard Sandy Shale	312	327
(6) pump 25 (HP) 620 (yield gpm) at	Peaked Sand	327	342
Electric 20# pressure (type power)	Rock	342	343
(7) electric log Yes (Yes or no)	Peaked Sand	343	358
Miss. Geol. Survey (organization running log)	Hard Sandy Shale	358	395
(8) how well bottom plugged Valve	Sand	395	410
	Hard Sandy Shale	410	414
	Sand	414	438
	Hard Sandy Shale	438	446
	Rock	446	447
	Sandy Shale, Rock / Shale	447	460
	Rock, Med. Hard	460	465
	Sandy Shale, Sand Rock	465	501
	Sand	501	517
	Sandy Shale, Hard Rock	517	539
	Peaked Sand Clay Sh	539	564
	Peaked Sand	564	595
	Sand	595	676
	Clay	676	680

DRILLERS REMARKS:
 Pump not installed as of this date - 70 feet

DEC 17 1968

MISS. BD. OF WATER COMM.