

Humphreys
 C 24
 7-9-70

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

BUDANE GAS CO

HUMPHREYS COUNTY

7/9/70
 date well completed

19 ~~7-9-70~~
 firm name

county well located

| LANDOWNER: PAUL TOWNSEND | description of formations encountered | from | to |
|---|---------------------------------------|------|-----|
| DEPOSIT GUARANTY BANK | CLAY | 0 | 17 |
| BELSONI MISS (mailing address) | SAND | 17 | 25 |
| | CLAY | 25 | 38 |
| | SAND | 38 | 70 |
| WELL LOCATION: sec 11 T. 26 N R. 3 W | SAND + GRAV. | 70 | 117 |
| 5 miles N of BELSONI (distance) (direction) (nearest town) | CLAY | 117 | 223 |
| | SAND | 223 | 275 |
| | SHALE | 275 | 323 |
| WELL PURPOSE: HOME (home, irrigation, municipal, industrial) | SHALES + SAND ST. | 323 | 371 |
| | HARD SHALE | 371 | 441 |
| | SAND + SHALES ST. | 441 | 617 |
| | SHALE | 617 | 691 |
| WELL COMPLETION DATA: (1) diameter (inches) 6 3/4 & 4 3/4 | HP. SAND | 691 | 774 |
| (2) total depth (feet) 787 | SHALE | 774 | 787 |
| (3) static water level (feet) 17 below top of ground @ 147' | | | |
| (4) casing 3" @ 100' (material) (depth) | | | |
| (size) If telescope see back. | | | |
| (5) screen 30' length, 736' depth to top | | | |
| (size) (material) 30 STAINLESS STEEL | | | |
| (6) pump 2 HP, 38 yield gpm | | | |
| (type power) 52EC | | | |
| (7) electric log NO (yes or no) | | | |
| (organization running log) | | | |
| (8) how well bottom plugged LEAD WOOD PLUGGED | | | |

CODED

DRILLERS REMARKS:

JUL 27 1970

MISS. RD. OR
 WATER COMM.