

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

P.O. Box 10631

Jackson, Mississippi 39209

WATER WELL DRILLERS LOG

CODED

COUNTY WELL LOCATED
Humphreys

WELL NUMBER **E 181** CODED

DATE WELL COMPLETED
3-21-90

PERMIT NUMBER **167D**

NAME OF DRILLING FIRM
IRRIGATION EQUIPMENT

601/887-2555

NAME & MAILING ADDRESS OF LANDOWNER
DENON BRASWELL

P.O. BOX 662

Belzoni, MS 39038

WELL LOCATION: SEC **33** TOWNSHIP **15** RANGE **4**

DISTANCE **2** MILES **south** DIRECTION of **Golden Lake** NEAREST TOWN

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Irrigation

PUMP DATA

PUMP TYPE (Circle One):
Submersible, **Turbine**, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, **Diesel**, Gasoline, Butane,
Other (Describe) **H/P 60**

Pump Capacity (GPM)	No. of Stages	Setting Depth
3000	1	60 FT.

PUMP TEST

Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 115	Casing Diameter (In.) 16	Casing Length (Ft.) 75
Type of Casing Steel	Hole Depth 115	Depth to Static Water Level 25'

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 16	Length - Feet 70	Slot Size - Inches .060
Screen Type STEEL	Depth to Bottom - Feet 115	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

RECEIVED

APR 17 1990

Department of Natural Resources
Bureau of Land & Water Resources

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (continued)	FROM	TO
clay	0	70			
COARSE SAND + GRAVEL	70	75			
medium SAND	75	85			
COARSE SAND + GRAVEL	85	115			

IF MORE SPACE IS NEEDED, USE BACK