MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Humphreys
WELL NUMBER: L-75 | CODED:
DATE WELL COMPLETED: Oct 25, 2000

PERMIT NUMBER: MS-GW-38834
NAME OF DRILLING FIRM: Schudco Ltd

NAME & MAILING ADDRESS OF LANDOWNER
Wayne Evans
130 Overlook Pointe Drive
Ridgeland Ms. 39097

WELL LOCATION: SEC 30 TOWNSHIP 13 (N) S RANGE 3 (E) W

DISTANCE ____ Miles DIRECTION ____ of NEAREST TOWN Yazoo City

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) ____

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) ____ H/P 30

Pump Capacity (GPM)	No. of Stages	Setting Depth
1600	1	60 FT.

PUMP TEST

Well yielded ____ GPM with a drawdown of ____ ft. after ____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
120	12	80

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	120	

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) ____

WELL GROUTED TO A DEPTH OF ____ FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) ____

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing ____ FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
12	40	.035

Screen Type	Depth to Bottom - Feet
PVC	120

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
clay	0	15
powder sand	15	30
course sand + p-gravel	30	70
med to course sand	70	80
Course sand + p-gravel	80	120

FORMATIONS (Continued)	FROM	TO

IF MORE SPACE IS NEEDED, USE BACK

RECEIVED
JUL 0 6 2001
YMD JOINT WATER MANAGEMENT DISTRICT