

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631

Jackson, MS 39289-0631

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED ISSAQUENA	
WELL NUMBER B-2620	CODED
DATE WELL COMPLETED 10-6-99	

PERMIT NUMBER
NAME OF DRILLING FIRM Schudco Ltd

NAME & MAILING ADDRESS OF LANDOWNER Sanders Seed HOLLANDALE MS			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	21	12	8
DISTANCE	DIRECTION	NEAREST TOWN	
3 Miles	South	Mayersville	
OTHER LANDMARK			
WELL PURPOSE: Home, Irrigation, Municipal, <u>Industrial</u> , Fish Pond, etc.			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) <u>no pump</u>		
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) <u>H/P</u>		
Pump Capacity (GPM)	No. of Stages	Setting Depth FT.
PUMP TEST		
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hrs. pumping		

WELL DATA		
Well Depth 100	Casing Diameter (In.) 4in	Casing Length (Ft.) 70
Type of Casing pvc	Hole Depth 100	Depth to Static Water Level 8 ft
TYPE OF COMPLETION: (Circle One or More): <u>Gravel Packed</u> , Underreamed, Telescoped, Natural Development, Open Hole, Other		
WELL GROUTED TO A DEPTH OF <u>10</u> FEET Type Grout (circle one): Cement, Bentonite, or Mix		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) <u>No Log Run</u>	
Name of Organization Running Log Dept. of Environmental Quality Office of Land & Water Resources	

SCREEN DATA		
Diameter - inches 4	Length - Feet 30	Slot Size - inches 1/8"
Screen Type pvc	Depth to Bottom - Feet 100	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			
Top of Lap Pipe or Reduction in Casing FEET IF TELESKOPED OR MORE THAN ONE SCREEN: USE BACK PAGE			

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
sand clay	0	8			
Gumbo	8	50			
medium to coarse sand and p-gravel	50	100			

IF MORE SPACE IS NEEDED, USE BACK