

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
OSAGE

WELL NUMBER
F 2008

DATE WELL COMPLETED
July 18, 1997

PERMIT NUMBER

NAME OF DRILLING FIRM
K M BIRD CRESSWELL

BENTONIA, MS-39040

NAME & MAILING ADDRESS OF LANDOWNER
Colemans Camp
Yazoo City, MS-

WELL LOCATION SEC **31** TOWNSHIP **9 N** RANGE **7W**

DISTANCE **6** Miles DIRECTION **WEST** NEAREST TOWN **VALLEY PARK**

OTHER LANDMARK

WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Camp-

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P

Pump Capacity (GPM) **25** No. of Stages **10** Setting Depth **42** FT.

PUMP TEST
Well yielded **50** GPM with
a drawdown of **10** ft.
after **1/2** hours of pumping

WELL DATA

Well Depth 110	Casing Diameter (In.) 4	Casing Length (Ft.) 90
Type of Casing PVC	Hole Depth 110	Depth to Static Water Level 14

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF **25** FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run,
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 4	Length - Feet 20	Slot Size - Inches .013
Screen Type PVC	Depth to Bottom - Feet 110	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
SURFACE DEPOSITS	0	16	RECEIVED AUG 07 1997 Dept. of Environmental Quality Office of Land & Water Resources		
SAND-GRAVEL	16	110			

IF MORE SPACE IS NEEDED, USE BACK