

ITAWAMBA MISSISSIPPI BOARD OF WATER COMMISSIONERS

~~662~~ **G62** CODED


1-11-66

WATER WELL DRILLERS LOG

Date: 1-11- 5, 1966, Driller: Carloss Well Supply County Shelby *Itawamba*

(Name)

(1) Owner of Land:	Description & Color of Materials Sand, Clay, Red Clay, Shell, etc.	Thick- ness Feet	Depth Feet
City of Fulton	Sandy Clay	20	20'
Itawamba County	Thin Rock Layer	5	25'
Fulton, Mississippi	Blue Clay	12'	37'
East Side of North Cummings St.	Clay w/ Strks. Gravel	20'	57'
(2) Location: <u>SE 1/4, SW 1/4, Sec. 19 T9 R9E</u>	Very Hard Shale	16'	73'
950 North of Vollege Street.	White Clay	27'	100'
_____ miles _____ of <u>FULTON</u>	Sandy Clay	15'	115'
(distance) (direction) (Nearest Town)	Very Hard Shale	20'	135'
(3) Topography: _____	Sand & Gravel	10'	145'
(Hilly) (Flat) (Level)	Broken Rock	23'	168'
(4) Purpose of Well: <u>Municipal</u>	Gravel, Very Little Sand	32'	200'
(Domestic Irrigation Municipal, Industrial, Other)	Sand & Small Gravel	13'	213'
Information upon completion of well:	Fine Sand	8'	221'
(1) Diameter <u>10"</u> inches.	Hard Shale, Thin Layers		
(2) Total Depth <u>200</u> feet.	Soft Rock -- Occasional		
(3) Water Level <u>32'-34'</u> feet below top of ground.	Strk. of Sandy Shale	79'	300'
(4) Cased to <u>159'</u> , Size <u>10" I.D.</u>			
(5) Screen: Size <u>6"</u> , Length <u>31'</u>			
(6) Were any formations sealed against pollution?			
Yes --			
Casing Cemented Entire Length			
yes, no.			
If YES depth of formation _____			
Why _____			
Drillers Remarks: _____			



I 20

(Use Back Side)

Well No.

Retain this copy for your office files.