

ITTAWAMBA
 N 21
 7-30-69

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

7-30 1969 W. J. REEVES & SON ITTAWAMBA
 date well completed firm name county well located

| LANDOWNER: <u>HERSHEL BLAKE</u> | description of formations encountered | from | to |
|---|---------------------------------------|------------|------------|
| <u>RT. 1</u> | | | |
| <u>NETTLETON</u> (mailing address) | <u>RED CLAY</u> | <u>0</u> | <u>22</u> |
| | <u>RED SD + CLAY</u> | <u>22</u> | <u>110</u> |
| | <u>BLUE CLAY</u> | <u>110</u> | <u>112</u> |
| WELL LOCATION: sec <u>23</u> T <u>11</u> S R <u>8</u> E <u>5</u> miles <u>NW</u> of <u>SMITHVILLE</u> (distance) (direction) (nearest town) | | | |
| WELL PURPOSE: <u>HOME</u> (home, irrigation, municipal, industrial) | | | |
| WELL COMPLETION DATA: | | | |
| (1) diameter (inches) <u>4</u> | | | |
| (2) total depth (feet) <u>112</u> | | | |
| (3) static water level (feet) <u>74</u> below top of ground. | | | |
| (4) casing <u>PVC</u> , <u>92</u> (material) (depth) | | | |
| <u>4</u> if telescope see back. (size) | | | |
| (5) screen <u>20</u> , <u>92</u> (length) (depth to top) | | | |
| <u>4</u> , <u>PVC</u> (size) (material) | | | |
| (6) pump <u>3/4</u> , <u>12</u> (HP) (yield gpm) | | | |
| <u>ELECT</u> (type power) | | | |
| (7) electric log <u>NO</u> (yes or no) | | | |
| (organization running log) | | | |
| (8) how well bottom plugged <u>SAND</u> | | | |
| DRILLERS REMARKS: | | | |

CODED

SEP - 2 1969

MISS. REG. OF WATER CONTROL