

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
JACKSON

WELL NUMBER **A 49** CODED

DATE WELL COMPLETED
1-2-95

PERMIT NUMBER

NAME OF DRILLING FIRM
Coastwater Well Service

NAME & MAILING ADDRESS OF LANDOWNER
Carl Fairley
Vestry Rd.
Vancleave, Ms

WELL LOCATION SEC TOWNSHIP RANGE
SE NW 3 4 8 8

DISTANCE DIRECTION NEAREST TOWN
14 Miles **NORTH** of **Vancleave**

OTHER LANDMARK

WELL PURPOSE Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P

Pump Capacity (GPM) No. of Stages Setting Depth FT.

PUMP TEST
Well yielded GPM with
a drawdown of ft.
after hours of pumping

WELL DATA

Well Depth 90'	Casing Diameter (In.) 2"	Casing Length (Ft.) 80'
Type of Casing PVC	Hole Depth 90'	Depth to Static Water Level 16'

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other

WELL GROUTED TO A DEPTH OF **20** FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 2"	Length - Feet 10'	Slot Size - Inches .008
Screen Type PVC	Depth to Bottom - Feet 90'	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Top Soil	0	1
Red Clay gravel	1	15
White Coarse sand	15	28
Blue	28	36
Grey Medium Sand	36	90

FORMATIONS (Continued)	FROM	TO
RECEIVED		
FEB 14 1995		
Dept. of Environmental Quality Office of Land & Water Resources		
IF MORE SPACE IS NEEDED, USE BACK		

