

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Jackson

WELL NUMBER **B 2029** CODED

DATE WELL COMPLETED
1-14-99

PERMIT NUMBER

NAME OF DRILLING FIRM
Coast Water Well Service

NAME & MAILING ADDRESS OF LANDOWNER
Ernest Applwhite
Cedar Creek Estates
Pascagoula, Ms

WELL LOCATION: SEC **38** TOWNSHIP **4^N** RANGE **7^E**

DISTANCE **6** Miles DIRECTION **NNW** of NEAREST TOWN **Wade**

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Camp

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, **Flowing Well**, Other (Describe) _____

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P **1/2**

Pump Capacity (GPM) **7** No. of Stages **1** Setting Depth _____ FT.

PUMP TEST
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth 300'	Casing Diameter (in.) 2"	Casing Length (Ft.) 290'
Type of Casing PVC	Hole Depth 300'	Depth to Static Water Level 5'

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) **No Log Run**

Name of Organization Running Log

TYPE OF COMPLETION: (Circle One or More):
Natural Development, Gravel Packed, Underreamed, Telescoped, Open Hole, Other

WELL GROUTED TO A DEPTH OF **20** FEET
Type Grout (circle one): **Cement**, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA

Diameter - Inches 2"	Length - Feet 10'	Slot Size - Inches .008
Screen Type PVC	Depth to Bottom - Feet 300'	

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Top Soil	0	2
White Coarse sand	2	60
Blue Clay	60	65
Med Coarse sand	65	80
Blue Clay Str. sand	80	280
Gray Coarse sand	280	300

RECEIVED

APR 05 1999

**Dept of Environmental Quality
Office of Land & Water Resources**

IF MORE SPACE IS NEEDED, USE BACK

