

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Jackson
WELL NUMBER *D95* CODE
DATE WELL COMPLETED
8/12/96

PERMIT NUMBER
NAME OF DRILLING FIRM
Pieci

NAME & MAILING ADDRESS OF LANDOWNER
Hurley Fire Dept.
Hurley, MS
WELL LOCATION SEC TOWNSHIP RANGE
N6 2W 33 4 N 5 E
DISTANCE MILES DIRECTION NEAREST TOWN
— Miles *—* of *In Hurley*
OTHER LANDMARK
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Fire Dept.

PUMP DATA
PUMP TYPE (Circle One): Submersible Turbine, Jet, Flowing Well, Other (Describe)
POWER TYPE (Circle One): Electric Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 3
Pump Capacity (GPM) No. of Stages Setting Depth
70 *8* *40* FT.
PUMP TEST
Well yielded 70 GPM with a drawdown of 10 ft. after 1 hours of pumping

WELL DATA
Well Depth *50'* Casing Diameter (In.) *4"* Casing Length (Ft.) *40'*
Type of Casing *Plastic* Hole Depth *50'* Depth to Static Water Level *20'*

LOG DATA
TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)
Name of Organization Running Log

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

WELL GROUTED TO A DEPTH OF 12 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA
Diameter - Inches *4"* Length - Feet *10'* Slot Size - Inches *006*
Screen Type *Plastic* Depth to Bottom - Feet *50'*

Driller's Remarks
Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<i>Top soil</i>	<i>0</i>	<i>10</i>
<i>Clay</i>	<i>10</i>	<i>20</i>
<i>Sand good</i>	<i>20</i>	<i>50</i>

FORM 100 (Continued) FROM TO
RECEIVED
JW
JAN 03 1997
Dept. of Environmental Quality
Office of Land & Water Resources
IF MORE SPACE IS NEEDED, USE BACK

