

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Jackson

WELL NUMBER CODED
D 2036

DATE WELL COMPLETED
3-19-99

PERMIT NUMBER
1

NAME OF DRILLING FIRM
Pierce Well

NAME & MAILING ADDRESS OF LANDOWNER
Jerry Pierce
Harleston
Pascagoula, MS

WELL LOCATION SEC TOWNSHIP RANGE
8 4 N 5 W

DISTANCE DIRECTION NEAREST TOWN
2 Miles S of Georgetown

OTHER LANDMARK
Line

WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 1

Pump Capacity (GPM) No. of Stages Setting Depth
10 2 30' FT.

PUMP TEST

Well yielded 10 GPM with a drawdown of 10 ft. after 1 hours of pumping

WELL DATA

Well Depth Casing Diameter (In.) Casing Length (Ft.)
48' 2" 38'

Type of Casing Hole Depth Depth to Static Water Level
Plastic 48' 20'

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____

WELL GROUTED TO A DEPTH OF 15 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____

Name of Organization Running Log

SCREEN DATA

Diameter - Inches Length - Feet Slot Size - Inches
2" 10 006

Screen Type Depth to Bottom - Feet
Plastic 48'

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>Topsoil</u>	<u>0</u>	<u>10</u>
<u>clay & sand</u>	<u>10</u>	<u>25</u>
<u>good sand</u>	<u>25</u>	<u>48</u>

FORMATIONS (Continued)	FROM	TO

RECEIVED

MAY 27 1999

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK

