

JACKSON
F65
3-3-72

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

CODED

3-3-72
 date well completed

J. I. Ward Water Well Jackson
 firm name county well located

LANDOWNER: Kenneth McALE

John Bayou Road
Vancleave Miss.
 (mailing address)

WELL LOCATION:

sec. 27 T. 5 N R. 7 E
 (distance) miles 7 miles N-E of VANCLEAVE
 (direction) (nearest town)

WELL PURPOSE: HOME
 (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 2
- (2) total depth (feet) 871
- (3) static water level (feet) 4 (below above top of ground.)
- (4) casing 2" galv. 861
 (material) (depth)
- if telescope see back.
 (size)
- (5) screen 10' -
 (length) (depth to top)
2" 8 galv. Stainless Steel
 (size) (material)
- (6) pump 1-2 hp. 9
 (HP) (yield gpm)
Elc.
 (type power)
- (7) electric log NO
 (yes or no)
N/A
 (organization running log)

description of formations encountered	from to	
Top Soil - clay	0	21
Red sd	21	33
Gray clay	33	96
Orange - sd	96	124
Blue clay	124	202
sd.	202	205
Silt - Blue clay	205	420
sd. - fine	420	427
Silt - Blue clay	427	632
sd. fine	632	644
Silt - Blue clay	644	832
sd - marlstone	832	871

CODED

APR 21 1972

DRILLERS REMARKS:

See Back

MISS. DIV. OF
 WATER COMM.

If well telescopes please sketch and show depths.

02000

GROUND LEVEL

SECTION 27

Please indicate well location X.

ADDITIONAL INFORMATION

Estimated depth to be around 350 feet. Did not encounter any sd. to amount of anything to around 332'. The sd. in the 200' - 400' - 600' was of a very fine nature. The sand we made the well in was much heavier. I still set an 3/8" ga. strainer & production was good.

02000

If more than one screen, show locations of each on sketch.