

State Well Report

Part 1

Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

For Office Use Only:

Aquifer: _____
Well #: F-301
L. S. Elevation: _____
E-log #: _____

County: JACKSON
Permit #: _____
Driller: Coast Water Well Serv.
Date drilling completed: 10-3-06

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.

Well Owner Information	Well Location
Owner Name: <u>Joey Rocko</u>	Latitude: <u>30° 38' 03" N</u> Longitude: <u>088° 41' 45" W</u>
Mailing Address: <u>Busby Rd.</u>	Method of Lat/Long (circle one): <u>Conventional Survey</u>
<u>Yanceville, MS 39565</u>	USGS quad, <u>(Hand-held GPS)</u> , Survey-grade GPS
City: _____ State: _____ Zip Code: _____	<u>SW</u> 1/4 <u>SW</u> 1/4 Sec <u>4</u> Twn <u>T55</u> Rng <u>R7W</u>
Telephone No. <u>(228) 623-2993</u>	Distance: <u>1 1/2</u> Miles Direction: <u>North</u> of Nearest Town: <u>Yanceville</u>

Well Data

Purpose of Well (circle one) Home Industrial Public Supply Irrigation Fish Culture Other: _____

Date well drilling started: 10-3-06 Date well drilling completed: 10-3-06

If flowing, method of flow regulation: Valve N/A Other (describe) _____

Static Water Level: 35 feet above or (below) (circle one) land surface Date measured: 10-3-06

Method of Measurement (circle one) steel tape electric tape air line other: _____

Hole depth: 529' Well depth: 529' Well grouted to a depth of 10 feet

Type of grout (circle one): Cement Bentonite Mix

Casing length: 514 feet Casing diameter: 2 inches Type of casing: PVC

Screen length: 15 feet Screen diameter: 2 inches Type of screen: PVC

Screen slot size: .0060 inches Setting depth: From 514 feet to 529 feet

Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development

Other (describe): _____

Top of lap pipe or reduction in casing: _____ feet. If telescoped or more than one screen, describe on back of page

Logs run (circle all applicable) No log run Electric Gamma Ray Density Sonic Neutron Other: _____

Name of organization running log(s): N/A

I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Jack Bidgdell 0-472
Print Name of Water Well Contractor and License No.

Jack Bidgdell
Signature of Water Well Contractor

RECEIVED
BY OLWF

STATE WELL REPORT

Part 2

Pump Installer's Completion Report
Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

For Office Use Only:

Aquifer: _____

Well #: F-301

Elevation: _____

County: Jackson

Permit #: _____

Driller: Coast Water Well Serv.

Date completed: 10-3-06

This report should be prepared by the pump installer in detail and filed with the Department within 30 days of the installation of pump.

Well Owner Information

Owner Name: Joey Racko

Mailing Address: Busby Rd.

Vancleave, MS 39565
City State Zip Code

Telephone No. 601-623-3993

Well Location

Latitude: 30°38'05.8" Longitude: 088°41'75.0"
03 45

Method of Lat/Long (circle one): Conventional Survey,

USGS quad, Hand-held GPS Survey-grade GPS

SW 1/4 SW 1/4 Sec 4 Twp 15 S Rng R 7W

Distance Direction Nearest Town
7 1/2 Miles N of Vancleave

Pump Type Circle one

Air Lift Jet Submersible
Bucket Piston Turbine
Centrifugal Rotary Flowing Well

Other (specify): _____

Date Pump Installed: 10-18-06

Rated Pump Capacity: 8 Gallons Per Minute

Power Type Circle one

Diesel Engine Gasoline Engine Natural Gas
 Electric Motor Hand Tractor PTO
Windmill Other (specify): _____

Horse Power Rating of Motor: 1 HP

Setting Depth: 60 FT. Drop pipe feet

Number of Stages: 2

Pump Test Data

Date Well Tested: 10-18-06

Static Water Level (A): 35 Feet Below Land Surface

Pumping Water Level (B): N/A Feet Below Land Surface

Drawdown [(B) - (A)]: N/A Feet Below Land Surface

Test Pumping Rate: 8 Gallons Per Minute

Duration of Pump Test (minimum 4 hours): 4 hours

Method of Measuring Water Level Circle one

Air Line Electric Measuring Line Steel Tape

Other (specify): _____

For flowing well, measured shut in head: N/A feet

Well yielded 8 GPM with a drawdown of

N/A feet after N/A hours of pumping

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.

Jack Biddell 0-472
Print Name of Pump Installer and License No. (if applicable)

Jack Biddell
Signature of Pump Installer

RECEIVED

10/18/06

BY: CLAN