

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Jackson

WELL NUMBER **F 2345** CODED

DATE WELL COMPLETED
8-25-97

PERMIT NUMBER

NAME OF DRILLING FIRM
Coast Water Well Service

NAME & MAILING ADDRESS OF LANDOWNER
Martha Turner
Longleaf Drive
Vancleave Miss

WELL LOCATION SEC TOWNSHIP RANGE
NE NE 29 5 S 7 E

DISTANCE DIRECTION NEAREST TOWN
3 Miles **NW** of **Vancleave**

OTHER LANDMARK

WELL PURPOSE Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Flowing Well, Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P **1**

Pump Capacity (GPM) No. of Stages Setting Depth
8 **2** _____ **FT.**

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth 110'	Casing Diameter (In) 2"	Casing Length (Ft) 100'
Type of Casing PVC	Hole Depth 110'	Depth to Static Water Level 40'

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, No Log Run, Neutron, Other (Describe) _____

Name of Organization Running Log

WELL GROUTED TO A DEPTH OF **30** FEET
Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches 2"	Length - Feet 10'	Slot Size - Inches .008
Screen Type PVC	Depth to Bottom - Feet 110'	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Red Sand	0	9
Red Clay	9	70
White Coarse Sand	70	110

FORMATIONS (Continued)	FROM	TO

RECEIVED

OCT 27 1997

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK

