

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

OPUNITY WELL LOCATED
Jackson

WELL NUMBER **2237** CODED

DATE WELL COMPLETED **4-10-87**

PERMIT NUMBER

NAME OF DRILLING FIRM
Coast Water Well Svc. Inc.

NAME & MAILING ADDRESS OF LANDOWNER
William Bates
Seaman Rd
Vancleave Mo

WELL LOCATION: SEC **14** TOWNSHIP **6^N** RANGE **8^E**

DISTANCE **4** Miles **W** of **Vancleave**

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
home

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, **JBT** Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
Electric Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____

Pump Capacity (GPM) 8	No. of Stages 1	Setting Depth - FT.
---------------------------------	---------------------------	-------------------------------

PUMP TEST

Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 70' 5"	Casing Diameter (In.) 2"	Casing Length (Ft.) 55'
Type of Casing PVC	Hole Depth 70'	Depth to Static Water Level 7'

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, **No Log Run**, Neutron,
Other (Describe) _____

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 2"	Length - Feet 10'	Slot Size - Inches .008
Screen Type PVC	Depth to Bottom - Feet 65'	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Top Soil	0	2
Brown Clay	2	25
Gray Fine Sand	25	35
Gray Coarse Sand	35	65
Blue Clay	65	70

FORMATIONS (Continued)

MAY 21 1987

Department of Natural Resources
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK

