

**MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY**  
**Office of Land and Water Resources**  
**P. O. Box 2309**  
**Jackson, MS 39225**  
**Water Well Plugging/Decommissioning Form**  
**OLWR-DF-1 (04/08)**

059 K0245 (maybe K117)

COUNTY WELL LOCATED: Jackson		WELL NUMBER: Unknown	
PERMIT NUMBER: 0-647		DATE WELL PLUGGED: 12/12/13	
NAME OF FIRM PLUGGING WELL: Neel-Schaffer, Inc.		TELEPHONE NUMBER: 601-898-3358	
NAME AND ADDRESS OF CURRENT LANDOWNER: Mississippi Department of Transportation (MDOT) P.O. Box 1850, Jackson, MS 39215			
WELL LOCATION: SECTION: 20 TOWNSHIP: 6 S RANGE: 7 W			
WELL LOCATION: LATITUDE: 30-30-37.9 LONGITUDE: 88-42-16.9 METHOD (CIRCLE ONE): (1) USGS QUAD (2) CONVENTIONAL SURVEY (3) GPS - HAND HELD OR SURVEY GRADE			
DISTANCE: app. 2.5 mi. DIRECTION: SSW NEAREST TOWN: Vancleave OTHER LANDMARK: MDOT Parcel 018-0-00-W			
WELL PURPOSE (HOME, IRRIGATION, MUNICIPAL, ETC.): Home			
NAME OF WELL CONTRACTOR WHO DRILLED THE WELL: Unknown			
NAME OF LANDOWNER WHEN WELL WAS DRILLED: Owner prior to MDOT acquisition was Douglas Stewart Bosarge 11505 Highway 57, Vancleave, MS			

WELL DATA			
WELL DEPTH: 300+ ft		HOLE DEPTH: Unknown	
CASING DIAMETER (IN.): 2	CASING LENGTH (FT.): Unknown	TYPE OF CASING: PVC	
DEPTH TO STATIC WATER LEVEL: 81.3 ft		DATE WELL COMPLETED: Unknown	
WHY IS THE WELL BEING ABANDONED? MDOT acquired property for future highway construction			

DESCRIBE HOW THE WELL OR HOLE WAS PLUGGED (AMOUNT OF CASING AND/OR SCREEN THAT WAS REMOVED OR LEFT IN HOLE, MATERIAL AND AMOUNT USED IN PLUGGING, METHOD OF PLACING MATERIAL, ETC.)

The abandonment procedure was discussed with James Crawford and Tommie Whitten, Mississippi Department of Environmental Quality, Office of Land and Water Resources. The grout was mixed in approximate proportions of 94 lbs Portland cement, 5 lbs granulated bentonite, and 8 gallons of water. Installed 100 ft of tremie pipe in well casing, pumped grout through tremie pipe until grout return from well casing, removed tremie pipe, cut well casing off approximately one foot below grade, grouted around outside of well casing to depth of approximately one foot below grade, topped off grout the next day. Well grouted in place.

I CERTIFY THAT THE WELL WAS PLUGGED OR ABANDONED IN ACCORDANCE WITH THE STATE OF MISSISSIPPI REGULATIONS.	
B. Gregory Taylor	0-647
PRINT NAME	MS LICENSE NUMBER
<i>B. Gregory Taylor</i>	12-30-13
SIGNATURE	DATE

**RECEIVED**  
 JAN 03 2014  
 BY: OLWR