

# State Well Report

## Part 1

Mississippi Department of Environmental Quality  
Office of Land and Water Resources  
P.O. Box 10631  
Jackson, MS 39289-0631  
(601)961-5210  
(601)354-6938 (fax)

### For Office Use Only:

Aquifer: \_\_\_\_\_  
Well #: K-448  
L. S. Elevation: \_\_\_\_\_  
E-log #: \_\_\_\_\_

County: Jackson 059  
Permit #: \_\_\_\_\_  
Driller: Coast Water Well Service  
Date drilling completed: 1-14-05

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.

Well Owner Information	Well Location
Owner Name: <u>Teleco, Inc.</u>	Latitude: <u>30° 31' 72"</u> Longitude: <u>088° 43' 28"</u>
Mailing Address: <u>Seaman RD</u>	Method of Lat/Long (circle one): <u>Conventional Survey</u>
<u>Ocean Springs MS 39565</u>	USGS quad, <u>(Hand-held GPS)</u> Survey-grade GPS
City State Zip Code	<u>NE 1/4 NW 1/4 Sec 18 Twn 76S Rng R 7W</u>
Telephone No. <u>(228) 341-5698</u>	Distance Direction Nearest Town
	<u>2 Miles West of Vancleave</u>

### Well Data

Purpose of Well (circle one) Home Industrial Public Supply Irrigation Fish Culture Other: \_\_\_\_\_  
Date well drilling started: 1-14-05 Date well drilling completed: 1-14-05  
If flowing, method of flow regulation: Valve N/A Other (describe) \_\_\_\_\_  
Static Water Level: 90 feet above or below (circle one) land surface Date measured: 1-14-05  
Method of Measurement (circle one) steel tape electric tape air line other: \_\_\_\_\_  
Hole depth: 336' Well depth: 336' Well grouted to a depth of 10 feet  
Type of grout (circle one): Cement Bentonite Mix  
Casing length: 321 feet Casing diameter: 2 inches Type of casing: PVC  
Screen length: 15 feet Screen diameter: 2 inches Type of screen: PVC  
Screen slot size: .006 inches Setting depth: From 321 feet to 336 feet  
Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development  
Other (describe): \_\_\_\_\_  
Top of lap pipe or reduction in casing: N/A feet. If telescoped or more than one screen, describe on back of page  
Logs run (circle all applicable) No log run Electric Gamma Ray Density Sonic Neutron Other: \_\_\_\_\_  
Name of organization running log(s): N/A

I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Jack Ridgell 0-472

Print Name of Water Well Contractor and License No.

Jack Ridgell

Signature of Water Well Contractor

If well telescopes please sketch below and show depths.

Ground Level K-448

Description of Formations Encountered	From	To
Top Soil	0	2
Orange Clay	2	18
Brown Coarse Sand	18	40
Orange + Blue Clay	40	100
Brown Coarse Sand	100	160
Blue Clay	160	300
Gray Medium Sand	300	336

If more than one screen, show location of each on sketch

Sketch the property layout and include the following: 1) the well location; 2) any permanent structures on the property that may aid in locating the well; 3) any roads, power lines, or other items that may aid in locating the property and the well; 4) indicate direction.

Landowner Name: Teleco, Inc.

Jack Rutledge  
Signature of Water Well Contractor

# STATE WELL REPORT

## Part 2

**Pump Installer's Completion Report**  
 Mississippi Department of Environmental Quality  
 Office of Land and Water Resources  
 P.O. Box 10631  
 Jackson, MS 39289-0631  
 (601)961-5210  
 (601)354-6938 (fax)

County: JACKSON  
 Permit #: \_\_\_\_\_  
 Driller: COASTWATER Well Serv.  
 Date completed: 1-14-05

For Office Use Only:

Aquifer: \_\_\_\_\_  
 Well #: K-448  
 Elevation: \_\_\_\_\_

**This report should be prepared by the pump installer in detail and filed with the Department within 30 days of the installation of pump.**

Well Owner Information	Well Location
Owner Name: <u>Teleco INC</u>	Latitude: <u>30.31° 722'</u> Longitude: <u>088° 43' 727'</u>
Mailing Address: <u>Seaman RD</u>	Method of Lat/Long (circle one): Conventional Survey, USGS quad, <u>Hand-held GPS</u> , Survey-grade GPS
<u>Vanderveave MS 39565</u> City State Zip Code	<u>NE 1/4 NW 1/4 Sec 18 Twn T6S Rng R7W</u>
Telephone No. <u>(228) 875-0260</u>	Distance Direction Nearest Town <u>2 Miles West of Vanderveave</u>

Pump Type Circle one	Power Type Circle one
Air Lift <input checked="" type="radio"/> <u>Jet</u> Submersible	Diesel Engine Gasoline Engine Natural Gas
Bucket Piston Turbine	<input checked="" type="radio"/> <u>Electric Motor</u> Hand Tractor PTO
Centrifugal Rotary Flowing Well	Windmill Other (specify): _____
Other (specify): _____	Horse Power Rating of Motor: <u>1 HP</u>
Date Pump Installed: <u>1-20-05</u>	Setting Depth: <u>120' drop pipe</u> feet
Rated Pump Capacity: <u>6</u> Gallons Per Minute	Number of Stages: <u>2</u>

Pump Test Data	Method of Measuring Water Level Circle one
Date Well Tested: <u>1-20-05</u>	<input checked="" type="radio"/> <u>Air Line</u> Electric Measuring Line Steel Tape
Static Water Level (A): <u>90</u> Feet Below Land Surface	Other (specify): _____
Pumping Water Level (B): <u>N/A</u> Feet Below Land Surface	For flowing well, measured shut in head: <u>N/A</u> feet
Drawdown [(B) - (A)]: <u>N/A</u> Feet Below Land Surface	Well yielded <u>6</u> GPM with a drawdown of
Test Pumping Rate: <u>6</u> Gallons Per Minute	<u>N/A</u> feet after <u>N/A</u> hours of pumping
Duration of Pump Test (minimum 4 hours): <u>17</u> hours	

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.

JACK RIDGELL 0-472 Jack Ridgell  
 Print Name of Pump Installer and License No. (if applicable) Signature of Pump Installer

**RECEIVED**  
 FEB 10 2005  
**BY: OLWR**