State Well Report For Office Use Only:						
County: Jackson	Par		For Office Use Only:			
Miss	Mississippi Department of Environmental Quality Office of Land and Water Resources		Aquifer:			
Permit #:	Office of Land and P.O. Box		Well #: K- 460			
Driller. Coast Water Well Srv	Jackson, MS		L. S. Elevation:			
Date drilling completed: 4-05-05	(601)96					
	(601)354-	6938 (fax)	E-log #:			
State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.						
Well Owner Information		Well Location				
Owner Name Johnny Mizelle		Latitude 30 • 30 · 893 " Longitude 088 • 38 · 456"				
Mailing Address: Vann Rd		Method of Lat/Long (circle one): Conventional Survey,				
		USGS quad, (Hand-held	GPS Survey-grade GPS			
Vancleave Ms c	39565 Zip Code	NE 1/2 NW 1/4 Sec 24 Twn 765 Rng R7W				
Telephone No. (228) 860-3706	• • • • • • • • • • • • • • • • • • •		Nearest Town of Vareleave			
	Well Da	ta .				
			Other			
Purpose of Well (circle one Home Industrial		Irrigation Fish Culture				
Date well drilling started: 4-22-05	1.1	•				
If flowing, method of flow regulation: Valve	N/A Other (des	cribe)				
Static Water Level: 45 feet above or below (circle one) land surface Date measured: 4-22-05						
Method of Measurement (circle one) steel tape electric tape air line other:						
Hole depth: 179' Well depth: 179' Well grouted to a depth of 10 feet						
	ntonite Mix					
Casing length: 169feet Casing diameter: 2inches Type of casing:PVC						
Screen length: 10 feet Screen diameter: 2 inches Type of screen: PVC						
Screen slot size: 1000 inches Se	Screen slot size: 100 inches Setting depth: From 169 feet to 179 feet					
Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development						
Other (describe):						
Top of lap pipe or reduction in casing: N/A feet. If telescoped or more than one screen, describe on back of page						
Logs run (circle all applicable) No log run Electric Gamma Ray Density Sonic Neutron Other:						
Name of organization running log(s): N/A I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi						
Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws						
Jack Ridgold 0-472		_ Jan	photolell			
Print Name of Water Well Contractor and Licens	se No.	Signature of	Water Well Contractor LCEIVED			
		·	MAY 1 8 2005			

BY: OLWR

Ground Level	Description of Formations Encountered From		
Ground Level	TOUSOIL	10	To
	rang clay	2	18
· · · · · · · · · · · · · · · · · · ·	Grown Course Sand	18	40
	rappe + white Clay	40	80
$oldsymbol{\ell}$	mun Medium Sand	80	1/6
	Blue Clay	1/6	168
G G	ray Modium Sand	168	1:19
ļ			
ļ			
If more than one screen, show location of each on sketch			

If more than one screen, show location of each on sketch

Sketch the property layout and include the following	g: 1) the well	location: 2) any permanent str	nictures on the property that may
aid in locating the well; 3) any roads,			
4) indicate direction.		Ť	3 1 1 7
İ	1		
	1		House
	1		
	1		
	1		x well
	1		X WOO
	ان	. 1 0	
	9	WAN RD	
A	\ -	U-1.	
1	- 1		
	aroc		
	4		
	100		
(19)	6		
	31		
	18		
	161		
	* •		
T-1 .00:			
Landowner Name: Johnny Mize	elle		

Signature of Water Well Contractor

RECEIVED

MAY 1 8 2005

BY: OLWR

STATE WELL REPORT						
County: Jackson Permit #: Driller: Cast Water Well Srv Date completed: 4-22-05	Part 2 Pump Installer's Completion Report Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Jackson, MS 39289-0631 (601)961-5210 (601)354-6938 (fax)		For Office Use Only: Aquifer: Well #: Elevation:			
This report should be prepared by the pump installer in detail and filed with the Department within 30 days of the						
installation of pump. Well Owner Information		Well Location				
Owner Name: Johnny Mizelle		Latitude: 30°30′893″ Longitude: 088°38′456′′				
Mailing Address: Vann Rd		Method of Lat/Long (circle one): Conventional Survey,				
		USGS quad, Hand-held GPS Survey-grade GPS				
Vancleave MS 39565 City State Zip Code		NE 14 NW 14 Sec 24 Twn 768 Rng R7W Distance Direction Nearest Town				
Telephone No. (208) 860-3206			NANCIEAVE			
Pump Type Circle one		Power Type Circle one				
Air Lift Jet	Submersible	Diesel Engine Gasolin	e Engine Natural Gas			
Bucket Piston	Turbine	Electric Motor Hand	Tractor PTO			
Centrifugal Rotary	Flowing Well	Windmill Other (specify):			
Other (specify):		Horse Power Rating of Motor:				
Date Pump Installed: 4-33-6		Setting Depth: 60FT DOPPIPE feet				
Rated Pump Capacity:	Gallons Per Minute	Number of Stages:	2			
Pump Test Data		Method of Measuring Water Level Circle one				
Date Well Tested: 4-23-05						
Static Water Level (A): 45 Feet Below Land Surface		Air Line Electric Measuring Line Steel Tape Other (specify):				
Pumping Water Level (B): N/A Feet Below Land Surface		F. G. i				
Drawdown [(B) – (A)]: NA Feet		For flowing well, measured sh	,			
Test Pumping Rate:		Well yielded				
Duration of Pump Test (minimum 4 hours):	4 hours	N//T feet after	N/A hours of pumping			

Signature of Pump Installer RECEIVED I HEREBY CERTIFY that the above statements are true to the best of my knowledge. Print Name of Pump Installer and License No. (if applicable)

MAY 18 2005

BY: OLWR