

add loc

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

P.O. Box 10631

Jackson, Mississippi 39209

WATER WELL DRILLERS LOG

COUNTY WHERE LOCATED
Jackson

WELL NUMBER CODED
7-2248

DATE WELL COMPLETED
10-14-87

PERMIT NUMBER

NAME OF DRILLING FIRM
Coast Water Well Svc.

NAME & MAILING ADDRESS OF LANDOWNER
Elmer Casey
2300 Sargent Melain
Vanceave MS

WELL LOCATION: SEC **13** TOWNSHIP **6 N** RANGE **7 W**

DISTANCE **4** Miles DIRECTION **SE** of NEAREST TOWN **VANCEAVE**

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
home

PUMP DATA **1 1/2 sk**

PUMP TYPE (Circle One):
Submersible, Turbine, **Jet** Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric Tractor, Diesel, Gasoline, Butane,
Other (Describe)

Pump Capacity (GPM) **10'** No. of Stages **3** Setting Depth **—** FT.

PUMP TEST

Well yielded **—** GPM with
a drawdown of **—** ft.
after **—** hours of pumping

WELL DATA

Well Depth 140	Casing Diameter (In.) 2"	Casing Length (Ft.) 130
Type of Casing PVC	Hole Depth 140	Depth to Static Water Level 25'

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe)

Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) **No Log Run**

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 2"	Length - Feet 10'	Slot Size - Inches .008
Screen Type PVC	Depth to Bottom - Feet 140'	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Top Soil	0	2	RECEIVED MAY 24 1988 Department of Natural Resources Bureau of Land & Water Resources		
White Coarse Sand	2	30			
Blue Clay	30	20			
Green Brown Sand	130	130			
Red Brown Sand	130	140			

IF MORE SPACE IS NEEDED, USE BACK

