

Jackson
 N 212
 5-68

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

5-21-1968 date well completed
 TWIN OAKS SUBDIVISION firm name
 Jackson county well located

LANDOWNER: Belford and

description of formations encountered	from	to
<u>mixed</u>	<u>0</u>	<u>42</u>
<u>sand</u>	<u>42</u>	<u>52</u>
<u>clay</u>	<u>52</u>	<u>62</u>
<u>mixed</u>	<u>62</u>	<u>83</u>
<u>clay</u>	<u>83</u>	<u>126</u>
<u>fine sand</u>	<u>126</u>	<u>188</u>
<u>sand</u>	<u>188</u>	<u>200</u>
<u>good clay</u>	<u>200</u>	<u>207</u>
<u>mixed</u>	<u>207</u>	<u>269</u>
<u>clay</u>	<u>269</u>	<u>305</u>
<u>sand</u>	<u>305</u>	<u>310</u>
<u>mixed</u>	<u>310</u>	<u>350</u>
<u>clay</u>	<u>350</u>	<u>354</u>
<u>fine sand</u>	<u>354</u>	<u>370</u>
<u>mixed</u>	<u>370</u>	<u>391</u>
<u>clay</u>	<u>391</u>	<u>395</u>
<u>good sand</u>	<u>395</u>	<u>451</u>

Associates, Inc.
1029 Caillavet Street
Biloxi (mailing address) Miss.

WELL LOCATION:
 sec. 17 T. 7 S. R. 8 E. W.
4 miles N of OLEAN SPRINGS
 (distance) (direction) (nearest town)

WELL PURPOSE: Subdivision
 (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 4
- (2) total depth (feet) 541
- (3) static water level (feet) 17 below top of ground.
- (4) casing gal steel 501' (material) (depth)
4" (size) If telescope see back.
- (5) screen 40' (length) 501' (depth to top)
8 ga. (size) SS on pipe (material)
- (6) pump 5 (HP) 600 (yield gpm)
electric (type power)
- (7) electric log No (yes or no)
 (organization running log)
- (8) how well bottom plugged Back pressure valve

DRILLERS REMARKS:



