

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

RECEIVED
 P.O. Box 10631
 Jackson, MS 39289-0631
 WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Jackson
 WELL NUMBER CODED
N 2574
 DATE WELL COMPLETED
7-21-99
7-21-99

PERMIT NUMBER
 NAME OF DRILLING FIRM
Pierce Well

NAME & MAILING ADDRESS OF LANDOWNER
Johnny Naremore
Gulf Park Est.
Ocean Springs, Ms
 WELL LOCATION: SEC 11 TOWNSHIP 7 S RANGE 8 W
 DISTANCE DIRECTION NEAREST TOWN
2 Miles S of Hwy 90
 OTHER LANDMARK
 WELL PURPOSE Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA
 NOV 09 1999
 PUMP TYPE (Circle One):
 Submersible, Turbine, Jet Flowing Well,
 Other (Describe)
 POWER TYPE (Circle One):
Electric, Tractor, Diesel, Water, Butane,
 Other (Describe) H/P
 Pump Capacity (GPM) No. of Stages Setting Depth
10 2 20 FT.
 PUMP TEST
 Well yielded 10 GPM with
 a drawdown of 10 ft.
 after 1 hours of pumping

WELL DATA
 Well Depth Casing Diameter (In.) Casing Length (Ft.)
170' 2" 160'
 Type of Casing Hole Depth Depth to Static Water Level
Plastic 170 20'
 TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
 (Describe)

LOG DATA
 TYPE OF LOG RUN (Circle One):
 Electric, Gamma Ray, Density, Sonic, No Log Run, Neutron,
 Other (Describe)
 Name of Organization Running Log

WELL GROUTED TO A DEPTH OF 15 FEET
 Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks
 Top of Lap Pipe or Reduction in Casing
 FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA
 Diameter - Inches Length - Feet Slot Size - Inches
2" 10 006
 Screen Type Depth to Bottom - Feet
Plastic 170

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
<u>Topsoil</u>	<u>0</u>	<u>10</u>			
<u>Sand</u>	<u>10</u>	<u>20</u>			
<u>Clay</u>	<u>20</u>	<u>120</u>			
<u>good Sand</u>	<u>120</u>	<u>170</u>			

IF MORE SPACE IS NEEDED, USE BACK

