

JACKSON
 #157
 8-1-70

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

B-1 1970 C.T. Switzer Well Co. JACKSON
 date well completed firm name county well located

LANDOWNER First Miss. National Bank
GAULTIER BRANCH
Highway 90
Gautier, Miss.
 (mailing address)

WELL LOCATION:
 sec 36 T 7 M R 7 W
S W
1 miles W of GAULTIER
 (distance) (direction) (nearest town)

WELL PURPOSE: BANK
 (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

(1) diameter (inches) 4 1/2

(2) total depth (feet) 925'

(3) static water level (feet) -14 below
 top of ground.

(4) casing galv. 925'
 (material) (depth)
4x2 if telescope see back.
 (size)

(5) screen 20' 905'
 (length) (depth to top)
008 stainless steel
 (size) (material)

(6) pump 2 25
 (HP) (yield gpm)

ELEC
 (type power)

(7) electric log YES
 (yes or no)

(organization running log)

(8) how well bottom plugged leak
pressure valve

description of formations encountered	from	to
CLAY	1	20
MIXED	20	40
SAND	40	119
CLAY	119	193
SAND	193	317
MIXED	317	337
CLAY	337	396
SAND	396	416
MIXED	416	431
CLAY	431	455
MIXED	455	475
CLAY	475	495
SAND	495	510
CLAY	510	555
MIXED	555	595
SANDSTREAK	595	615
MIXED	615	635
CLAY	635	655
MIXED	655	676
CLAY + SHALE	676	697
CLAY	697	735
SHALE	735	755
CLAY	755	775
CLAY + SHALE	775	795
CLAY	795	834
SHALE	834	844
CLAY	844	874
SHALE	874	893
SAND	893	925

CODED

SEP 11 1970

DRILLERS REMARKS:

If well telescopes please sketch and show depths.

GROUND LEVEL

20' | 821 OF 2" GALV. | 84 OF 4" GALV. | SCREEN

SECTION _____

Please indicate well location X.

ADDITIONAL INFORMATION

If more than one screen, show locations of each on sketch.