

CODED

JACKSON

Q383

3-23-73

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

March 23 1973

Colville Water Supply

JACKSON

data well completed

firm name

county well located

LANDOWNER: <u>Hubert</u>	description of formations encountered	from	to
<u>COWART</u> <u>Orange Grove MS</u> (mailing address)	<u>SANDY Clay</u>	<u>0</u>	<u>32</u>
WELL LOCATION: sec <u>12</u> T <u>7</u> N R <u>4</u> E <u>9</u> miles <u>NE</u> of <u>M.P.</u> (distance) (direction) (nearest town)	<u>Clay</u>	<u>32</u>	<u>95</u>
WELL PURPOSE: <u>home</u> (home, irrigation, municipal, industrial)	<u>SAND</u>	<u>95</u>	<u>162</u>
WELL COMPLETION DATA:	<u>Clay</u>	<u>162</u>	<u>200</u>
(1) diameter (inches) <u>2</u>	<u>SAND</u>	<u>200</u>	<u>230</u>
(2) total depth (feet) <u>410</u>	<u>CLAY</u>	<u>230</u>	<u>347</u>
(3) static water level (feet) <u>17</u> <u>below</u> <u>above</u> top of ground.	<u>SAND</u>	<u>347</u>	<u>410</u>
(4) casing <u>PVC</u> <u>400</u> (material) (depth)			
_____ if telescope see back. (size)			
(5) screen <u>10'</u> <u>400</u> (length) (depth to top)			
<u>2"</u> <u>STAINLESS</u> (size) (material)			
(6) pump <u>1</u> <u>15</u> (HP) (yield gpm)			
_____ <u>elec</u> (type power)			
(7) electric log <u>NO</u> (yes or no)			
_____ (organization running log)			
(8) how well bottom plugged <u>BP Valve</u>			
DRILLERS REMARKS:			

CODED

