

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

COUNTY WELL LOCATED
WEST DAVIS

WELL NUMBER **A 34** CODE

DEC 25-5 #1

DATE WELL COMPLETED
11-7-92

PERMIT NUMBER
0-402

NAME OF DRILLING FIRM
Tom Gr. Hite

Water Well

290B P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER
ENRON OIL & GAS

1001 ESE Loop 323, Suite 410

Tyler, TX 75701

WELL LOCATION: SEC **26** TOWNSHIP **9** RANGE **19**

DISTANCE **6** MILES **N** DIRECTION of **PRETIOS** NEAREST TOWN

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Rig Supply

PUMP DATA

PUMP TYPE (Circle One):
 Submersible Turbine Jet Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric Tractor Diesel Gasoline Butane,
Other (Describe) H/P

Pump Capacity (GPM) **100** No. of Stages Setting Depth **FT.**

PUMP TEST

Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 200	Casing Diameter (in.) 4	Casing Length (ft.) 180
Type of Casing PVC	Hole Depth 200	Depth to Static Water Level 100

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed Underreamed Telescoped,
 Natural Development Open Hole Other
(Describe)

WELL GROUTED TO A DEPTH OF _____ FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run Electric Gamma Ray Density Sonic Neutron,
Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks
DENKMAN LUMBER Co 26-1
715' S & 820' W OF NE/CO#

SCREEN DATA

Diameter - Inches 4	Length - Feet 20	Slot Size - Inches .025
Screen Type PVC	Depth to Bottom - Feet 0	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Clay	0	10			
CLAY-GRAVEL	10	100			
SAND & GRAVEL	100	200			

RECEIVED

DEC 30 1992

Dept. of Environmental Quality
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK