1833'N+857'E of SW/Gr.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources
P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Jefferson Davis

WELL NUMBER: NO2 | CODE: A520 | PERMIT NUMBER: -402

NAME OF DRILLING FIRM: Tom Griffith

DATE WELL COMPLETED: 7/3/98

NAME & MAILING ADDRESS OF LANDOWNER
ENERGY Drilling
P.O. Box 905
Natchez MS 39120

WELL LOCATION: SEC 26 TOWNSHIP 9 (N) S RANGE 19 (E) W

DISTANCE: 8 Miles DIRECTION: N of NEAREST TOWN: Prentiss

OTHER LANDMARK:

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.: Rig supply

PUMP DATA

PUMP TYPE (Circle One): (Submersible), Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 5

Pump Capacity (GPM)	No. of Stages	Setting Depth
55		189 FT.

PUMP TEST
Well yielded 45 GPM with a drawdown of Airlift ft. after ____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
200	4	160

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	200	110

TYPE OF COMPLETION: (Circle One or More): (Gravel Packed), Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): (Cement), Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log:

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks:

08-17-98A09:48 RCVD

Top of Lap Pipe or Reduction in Casing: FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4	40	.025

Screen Type	Depth to Bottom - Feet
PVC	0

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
red sandy Clay	0	20
Clay	20	60
Sand	60	120
Coarse Sand & Fine Gravel	120	160
Fine Gravel	160	200

FORMATIONS (Continued)	FROM	TO

IF MORE SPACE IS NEEDED, USE BACK