

COUNTY WELL LOCATED
JEFF Davis

WELL NUMBER CODED
#5

DATE WELL COMPLETED
11-16-00

PERMIT NUMBER
A-2075

PERMIT NUMBER
0-60

NAME OF DRILLING FIRM
Raybon Drilling

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER
D & D Drilling Co.
P.O. Box 1634
Ferdiday, LA 71334-1634

WELL LOCATION: SEC TOWNSHIP RANGE
26 9 N 19 E

DISTANCE DIRECTION NEAREST TOWN
2 1/2 Miles S of Quinville

OTHER LANDMARK
Oilfield

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P 5

Pump Capacity (GPM) No. of Stages Setting Depth
50 147 FT.

PUMP TEST
Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth Casing Diameter (In.) Casing Length (Ft.)
160 4 140

Type of Casing Hole Depth Depth to Static Water Level
PVC 160 90

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches Length - Feet Slot Size - Inches
4 20 .020

Screen Type Depth to Bottom - Feet
PVC 160

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESKOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Topsoil	0	2	RECEIVED!		
Red dirt	2	15			
Sand	15	160			
NOV 27 2000					
Dept. of Environmental Quality Office of Land & Water Resources					
IF MORE SPACE IS NEEDED, USE BACK					