MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Jeff Davis

WELL NUMBER: A-2003-2078 | CODED:

DATE WELL COMPLETED: 8-15-00

PERMIT NUMBER: 0-60

NAME OF DRILLING FIRM: Rayburn Drilling, Inc.

NAME & MAILING ADDRESS OF LANDOWNER:
D & O Drilling
P.O. Box 1634
Fenriday, LA 71334-1634

WELL LOCATION: SEC 22 TOWNSHIP 9 (N) (S) RANGE 19 (E) (W)

DISTANCE: 3/4 Miles DIRECTION: S of NEAREST TOWN: Gwinville

OTHER LANDMARK:

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.: Oilfield

PUMP DATA

PUMP TYPE (Circle One): (Submersible) Turbine, Jet, Flowing Well, Other (Describe) _____

POWER TYPE (Circle One): (Electric) Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 5

Pump Capacity (GPM)	No. of Stages	Setting Depth
50		84 FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
100	4	80

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	100	20

TYPE OF COMPLETION: (Circle One or More): (Gravel Packed) Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____

Name of Organization Running Log:

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks:

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4	20	.020

Screen Type	Depth to Bottom - Feet
PVC	100

Top of Lap Pipe or Reduction in Casing: FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Sand	0	100

FORMATIONS ENCOUNTERED | FROM | TO

RECEIVED
AUG 18 2000
Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK