

COUNTY WELL LOCATED
Jeff Davis

WELL NUMBER
Frank Griffin

34-7 F74

DATE WELL COMPLETED
1-26-01

A-2090

PERMIT NUMBER
0-60

NAME OF DRILLING FIRM
Rayburn Drilling

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources
P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER
D & D Drilling Co.

P.O. Box 1634

Feriday, LA 71334-1634

WELL LOCATION SEC TOWNSHIP RANGE
34 9 19 E

DISTANCE DIRECTION NEAREST TOWN
2 1/2 Miles S of Swinville

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Oilfield

PUMP DATA

PUMP TYPE (Circle One):
 Submersible Turbine Jet Flowing Well, Other (Describe)

POWER TYPE (Circle One):
 Electric Tractor Diesel Gasoline Butane, Other (Describe) H/P **5**

Pump Capacity (GPM) No. of Stages Setting Depth
50 147 FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth 165	Casing Diameter (In.) 4	Casing Length (Ft.) 145
Type of Casing PVC	Hole Depth 165	Depth to Static Water Level 95

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed Underreamed Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF **10** FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 4	Length - Feet 20	Slot Size - Inches .020
Screen Type PVC	Depth to Bottom - Feet 165	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction In Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Topsoil	0	4			
Sand	4	122			
Gravel	122	165			

RECEIVED

FEB 06 2001

**Dept. of Environmental Quality
Office of Land & Water Resources**

IF MORE SPACE IS NEEDED, USE BACK