D-2015

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P O Box 10631
[illegible] 39289-0631
WATER WELL DRILLER'S LOG

RECEIVED
JUN 12 2000
Dept. of Environmental Quality
Office of Land & Water Resources

COUNTY WELL LOCATED: Jeff Davis

WELL NUMBER: Gwinville 1-11 #1 | CODED:

DATE WELL COMPLETED: 6-7-00

PERMIT NUMBER: 0-60

NAME OF DRILLING FIRM: Rayborn Drilling

NAME & MAILING ADDRESS OF LANDOWNER:
D & D Drilling
P.O. Box 1634
Ferriday, LA 71334-1634

WELL LOCATION: SEC 7 TOWNSHIP 8 (N) (S) RANGE 18 E (W)

DISTANCE: 10 Miles DIRECTION: N of NEAREST TOWN: Prentiss

OTHER LANDMARK:

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.: Oilfield

PUMP DATA

PUMP TYPE (Circle One): (Submersible) Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): (Electric) Tractor, Diesel, Gasoline, Butane, Other (Describe)

Pump Capacity (GPM)	No. of Stages	Setting Depth
50		126 FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
135	4	115

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	135	60

TYPE OF COMPLETION: (Circle One or More): (Gravel Packed) Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4	20	.020

Screen Type	Depth to Bottom - Feet
PVC	135

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing: FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Topsoil	0	4
Red Sand	4	40
Pea Gravel	40	135

FORMATIONS (Continued)	FROM	TO

IF MORE SPACE IS NEEDED, USE BACK