

Jefferson Davis

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631

Jackson, MS 39289-0631

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED 2		PERMIT NUMBER 0-586	
WELL NUMBER D-2023	CODED	NAME OF DRILLING FIRM James Wells	
DATE WELL COMPLETED 2-3-2001		Water Well Ser.	

NAME & MAILING ADDRESS OF LANDOWNER
Joewel Hertzog
RT 2 Box 123 A
Prentiss MS. 39474

WELL LOCATION: SEC 16 TOWNSHIP 2 S RANGE 18 E

DISTANCE 5 Miles EAST of Prentiss, MS.

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P

Pump Capacity (GPM)	No. of Stages	Setting Depth
		FT.

PUMP TEST

Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 100	Casing Diameter (In.) 4	Casing Length (Ft.) 70
Type of Casing PVC	Hole Depth 100	Depth to Static Water Level 27

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF 15 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

WELL GROUTED TO A DEPTH OF 15 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches 4	Length - Feet 30	Slot Size - Inches 008
Screen Type R.V.C.	Depth to Bottom - Feet 70-100	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
T. O.V. Soil	0	2	Casing 0-25 REC'D JUL 25 2001		
Red clay	2	20			
Sand	20	50			
Red sand	50	100			

IF MORE SPACE IS NEEDED, USE BACK PAGE