

COUNTY WELL LOCATED
 JENKINS Davis
 WELL NUMBER
 #2031
 COPEL
 DATE WELL COMPLETED
 1/30/92

PERMIT NUMBER
 0-402
 NAME OF DRILLING FIRM
 Tom Griffith
 Water Well, Inc.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
 Bureau of Land and Water Resources

P. O. Box 10631
 Jackson, MS 39289-0631
 WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER
 McKinley, Taylor
 Route 1, Box 76
 Oakdale, MS 39656
 WELL LOCATION: SEC 28 TOWNSHIP 6^N RANGE 19^E
 DISTANCE 5 Miles DIRECTION N of NEAREST TOWN Goss
 OTHER LANDMARK
 WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
 home

PUMP DATA
 PUMP TYPE (Circle One): Submersible Turbine, Jet, Flowing Well
 Other (Describe)
 POWER TYPE (Circle One): Electric Tractor, Diesel, Gasoline, Butane
 Other (Describe) H/P 3/4
 Pump Capacity (GPM) 8 No. of Stages Setting Depth 175 FT.
 PUMP TEST
 Well yielded 8 GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA
 Well Depth 200' Casing Diameter (In.) 4" Casing Length (Ft.) 180'
 Type of Casing PVC Hole Depth 200' Depth to Static Water Level 140'
 TYPE OF COMPLETION: (Circle One or More): Natural Development, Gravel Packed, Underreamed, Telescoped, Open Hole, Other
 (Describe)
 Top of Lap Pipe or Reduction in Casing
 FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA
 TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)
 Name of Organization Running Log

SCREEN DATA
 Diameter - Inches 4 Length - Feet 20 Slot Size - Inches .010
 Screen Type PVC Slot Depth to Bottom - Feet 200'

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

 Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
bad gravel	0	40
blue clay	40	80
sand	80	90
clay	90	100
clay	100	160
fine sand	160	180
good sand	180	200

FORMATIONS (Continued) FROM TO

RECEIVED

APR 20 1992

Dept. of Environmental Quality
 Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK