

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Jackson

WELL NUMBER
0-2033

DATE WELL COMPLETED
6-29-99

PERMIT NUMBER
0-586

NAME OF DRILLING FIRM
James Walls

Water Well Ser

NAME & MAILING ADDRESS OF LANDOWNER
Hollis Sanders
Rt 1 Box 150 A
Carson, MS

WELL LOCATION: SEC 31 TOWNSHIP 6 RANGE 18
N S E W

DISTANCE 6 Miles DIRECTION South W. of NEAREST TOWN Carson

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P 1

Pump Capacity (GPM) No. of Stages Selling Depth
FT.

PUMP TEST
Well yielded 15 GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 68 Ft. Casing Diameter (In.) 4 in. Casing Length (Ft.) 48

Type of Casing PVC Hole Depth 68 Ft. Depth to Static Water Level 45

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF 16 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 4 in. Length - Feet 20 Slot Size - Inches 80

Screen Type PVC 510T Depth to Bottom - Feet 48-68

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

IF TELESCOPED OR MORE THAN FEET USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>Top Soil</u>	<u>0</u>	<u>2</u>
<u>Red Clay</u>	<u>2</u>	<u>40</u>
<u>Pre-Hard</u>	<u>40</u>	<u>68</u>

RECEIVED

JUL 20 2000

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK PAGE