

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Jeff Davis

WELL NUMBER CODED
J-2037

DATE WELL COMPLETED
6-19-00

PERMIT NUMBER

NAME OF DRILLING FIRM
Thompson Bras

NAME & MAILING ADDRESS OF LANDOWNER
Greywolf
333 Texas St. Suite 925
Shreveport, LA 71101

WELL LOCATION: SEC TOWNSHIP RANGE
31 6 S 18 E

DISTANCE DIRECTION NEAREST TOWN
6 Miles SW of Bossfield

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Rig supply

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P

Pump Capacity (GPM)	No. of Stages	Setting Depth	FT.
---------------------	---------------	---------------	-----

PUMP TEST
Well yielded **60** GPM with a drawdown of **30** ft. after **airlift** hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
240	4	228
Type of Casing	Hole Depth	Depth to Static Water Level
PVC	243	226

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF **10 FEET**
Type Grout (circle one): Cement, Bentonite, **or Mix**

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, **No Log Run**, Neutron, Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4	20	.020
Screen Type	Depth to Bottom - Feet	
PVC 56+	240	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
sandy clay	0	30			
gravel	30	35			
white clay & limestone	35	195			
sand	195	243			

REC'D JUN 25 2001

IF MORE SPACE IS NEEDED, USE BACK