MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources
P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Jefferson
WELL NUMBER: L 2006 | CODED:
DATE WELL COMPLETED: 5-12-98
PERMIT NUMBER: 0-60
NAME OF DRILLING FIRM: Rayborn Drilling

NAME & MAILING ADDRESS OF LANDOWNER
Patsy Necaise
7449 Cedar Lane
Pass Christian, MS 39571

WELL LOCATION: SEC 12 TOWNSHIP 9 (N) S RANGE 4 (E) W
DISTANCE: 4 Miles DIRECTION: N of NEAREST TOWN: Pleasant Hill
OTHER LANDMARK:
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.: Home

PUMP DATA

PUMP TYPE (Circle One): (Submersible,) Turbine, Jet Flowing Well, Other (Describe) _____
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P _____

Pump Capacity (GPM)	No. of Stages	Setting Depth
10	12	270 FT.

PUMP TEST
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
275	4	260

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	275	240

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, (Natural Development) Open Hole, Other (Describe) _____

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): (Cement,) Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____
Name of Organization Running Log:

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4	15	.010

Screen Type	Depth to Bottom - Feet
PVC	275

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks:

Top of Lap Pipe or Reduction in Casing: FEET
IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Topsoil	0	2
Shale	2	197
Sand	197	207
Chalk	207	217
Ratty Sand	217	232
Chalk	232	260
Sand	260	275

FORMATIONS (Continued) | FROM | TO

05-13-98A09:34 RCVD

IF MORE SPACE IS NEEDED, USE BACK