

State Well Report

Part I

Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

For Office Use Only:

Aquifer: _____
Well #: P-12
L. S. Elevation: _____
E-log #: _____

County: Jefferson
Permit #: _____
Driller: JAMES WELLS
Date drilling completed: 5-18-07

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.

Well Owner Information	Well Location
Owner Name: <u>Carisa Galloway</u>	Latitude: _____ Longitude: _____
Mailing Address: <u>6596 Perth Rd</u>	Method of Lat/Long (circle one): Conventional Survey, USGS quad, Hand-held GPS, Survey-grade GPS
<u>Fayette</u> <u>MS</u> <u>39069</u> City State Zip Code	<u>1/4</u> <u>1/4</u> Sec. <u>13</u> Twn <u>8N</u> Rng <u>3E</u>
Telephone No. <u>(601) 786-8330</u>	Distance <u>25</u> Miles Direction <u>W</u> of Nearest Town <u>Brookhaven</u>

Well Data

Purpose of Well (circle one) Home Industrial Public Supply Irrigation Fish Culture Other: _____

Date well drilling started: 5-18-07 Date well drilling completed: 5-18-07

If flowing, method of flow regulation: Valve _____ Other (describe) _____

Static Water Level: 100 feet above or below (circle one) land surface Date measured: 5-18-07

Method of Measurement (circle one) steel tape electric tape air line other: _____

Hole depth: 250 Well depth: 250 Well grouted to a depth of 10 feet

Type of grout (circle one): Cement Bentonite Mix

Casing length: 230 feet Casing diameter: 4 inches Type of casing: PVC

Screen length: 20 feet Screen diameter: 4 inches Type of screen: PVC

Screen slot size: 008 inches Setting depth: From 230 feet to 250 feet

Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development

Other (describe): _____

Top of lap pipe or reduction in casing: _____ feet. If telescoped or more than one screen, describe on back of page

Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other: _____

Name of organization running log(s): _____

I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

JAMES WELLS 0-586
Print Name of Water Well Contractor and License No.

James Wells
Signature of Water Well Contractor

RECEIVED
JUN 08 2007
BY: OLWR

STATE WELL REPORT

Part 2

Pump Installer's Completion Report
Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

For Office Use Only:

Aquifer: _____

Well #: P-12

Elevation: _____

County: Jefferson

Permit #: _____

Driller: JAMES WELLS

Date completed: 5-18-07

This report should be prepared by the pump installer in detail and filed with the Department within 30 days of the installation of pump.

Well Owner Information

Owner Name: Carisa Galloway

Mailing Address: 6596 Perth Rd.

Fayette MS 39069
City State Zip Code

Telephone No. (601) 786-8330

Well Location

Latitude: _____ Longitude: _____

Method of Lat/Long (circle one): Conventional Survey,

USGS quad, Hand-held GPS, Survey-grade GPS

_____ 1/4 _____ 1/4 Sec 13 Twn 8N Rng 3E

Distance Direction Nearest Town

25 Miles W of Brookhaven

Pump Type Circle one

Air Lift

Jet

Submersible

Bucket

Piston

Turbine

Centrifugal

Rotary

Flowing Well

Other (specify): _____

Date Pump Installed: 5-18-07

Rated Pump Capacity: 12 Gallons Per Minute

Power Type Circle one

Diesel Engine

Gasoline Engine

Natural Gas

Electric Motor

Hand

Tractor PTO

Windmill

Other (specify): _____

Horse Power Rating of Motor: 1

Setting Depth: 150 feet

Number of Stages: 14

Pump Test Data

Date Well Tested: 5-18-07

Static Water Level (A): 100 Feet Below Land Surface

Pumping Water Level (B): 150 Feet Below Land Surface

Drawdown [(B) - (A)]: 110 Feet Below Land Surface

Test Pumping Rate: 17 Gallons Per Minute

Duration of Pump Test (minimum 4 hours): 4 hours

Method of Measuring Water Level Circle one

Air Line

Electric Measuring Line

Steel Tape

Other (specify): _____

For flowing well, measured shut in head: _____ feet

Well yielded 17 GPM with a drawdown of

10 feet after 4 hours of pumping

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.

JAMES WELLS 0-586
Print Name of Pump Installer and License No. (if applicable)

James Wells
Signature of Pump Installer

RECEIVED

JUN 08 2007

BY OLWR