

JONES
A54
11-30-70

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

11/30/70 19 J.R. Farber Waterwell Dr. Jones
date well completed firm name county well located

LANDOWNER: Barrie Hinton
Rt. 2 Taylorsville
(mailing address)

description of formations encountered	from	to
Red clay	0	30
Chalk Pump	30	50
Water Sand	50	80

WELL LOCATION:
sec 1 T 9 N R 14 E
3 miles south of Sumnerland
(distance) (direction) (nearest town)

WELL PURPOSE: Home
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 2"
- (2) total depth (feet) 80
- (3) static water level (feet) 40 below above top of ground.
- (4) casing Galv. 75
(material) (depth)
1/2" If telescope see back.
(size)
- (5) screen 5ft 80
(length) (depth to top)
1 1/2" Steel Gravel
(size) (material)
- (6) pump 3/4 6
(HP) (yield gpm)
Electric
(type power)
- (7) electric log (yes or no)
- (organization running log)
- (8) how well bottom plugged chalk

CODED

DEC 21 1970

MISS. BD. OF
WATER COMM.

DRILLERS REMARKS:

