

B24 JB
2-27-2002

PERMIT # MS-GW-01428

Well #1 5,300.50

Well #2 5,217.50

Add or Deduct 6.00

DEAN GRIDER WATER WELL SERVICE
COLUMBIA, MISSISSIPPI

September 21, 1965

LOG FORM

Name Shady Grove Water Works Association
Location Jones County, Mississippi
Engineer Chas. N. Clark Associates
Log Number Driller # 1 Dated 5/26/65
Water Well #1

WELL DATA

Size drilled hole 11" - Depth drilled hole 345' - Size well casing
6 5/8" O.D. - Type 5/16" wall - Weight 19.135 lb. per ft. - Length
well casing 345' - Cemented 100 sacks. - Size screen 4" I.D. "WW"
Type. - Manufactured by Johnson. - Slot size .003. - Material stainless
steel. - Length screen 30'. - Lap pipe size 4" I.D. - Lap pipe length
42'. - Type galvanized steel. - Distance to lap 312'. Distance to top
of screen 354'. - Distance to screen bottom 384'. - Type bottom back
wash valve. - Connection top of lap 4" x 6" L. & R. Lead Seal. - Static
water level 175.35.

PUMP DATA

Type submersible. - Make Feerless. - Serial number 260005. - Maximum
O.D. 5 11/16" - Number stages 3. - H.P. 15. - RPM 3500. - Base 3. -
Cycle 3. - Voltage 220. - Length drop pipe 273'. - Size drop pipe 2 1/2"
I.D., - Rated capacity 165 GPM. - Electric controls. General Electric
pumping plant panel consisting of manual disconnect switch with 3 fuses
a standard amagnetic contactor, three ambient sensitive adjustable quick
trip over load relays mounted in an outdoor cabinet with H-O-A selector
switch for Franklin 15 H.P. - 3/60/220 volt motor.

RECEIVED

FEB 14 2002

BY: OLWR