

DEAN GRIDER WATER WELL SERVICE
COLUMBIA, MISSISSIPPI

September 21, 1965

LOG FORM

Name Shady Grove Water Works Association
Location Jones County, Mississippi
Engineer Chas N. Clark Associates
Log Number Driller # 2 Dated 6/18/65
Water Well # 2

WELL DATA

Size drilled hole 11". - Depth drilled hole 330'. - Size well casing 6 5/8" O.D. - Type 5/16" wall. - Weight 19.185 lb. per ft. - Length well casing 330'. - Cemented 100 sacks. - Size screen 4" I.D. - Type "W W". - Manufactured by Cook. - Slot size .010. - Material stainless steel. - Length screen 30'. - Lap pipe size 4" I.D. - Lap pipe length 42'. - Type galvanized steel. - Distance to lap 298'. - Distance to top of screen 340'. - Distance to screen bottom 370'. - Type bottom back wash valve. - Connection top of lap 4" x 6". - L. & R. lead seal. Static water level 154.13.

PUMP DATA

Type submersible. - Make Peerless. - Serial number 2668095. - Maximum O.D. 5 11/16". - Number stages 3. - H.P. 15. - RPM 3600. - Phase 3. - Cycle 3. - Voltage 220. - Length drop pipe 273'. - Size drop pipe 2 1/2" I.D. - Rated capacity 165 GPM. - Electric controls. General Electric pumping plant panel consisting of manual disconnect switch, with 3 fuses a standard magnetic contactor, three ambient sensing adjustable quick trip over load relays mounted in an outdoor cabinet with H-O-A selector switch for Franklin 15 H.P. 3/60/220 volt motor.

RECEIVED

FEB 14 2002

BY: OLWR