

Jones Co
 C 100
 7-17-70

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

7/17 1970 C.P. Clark Jones
 date well completed firm name county well located

| LANDOWNER: | description of formations encountered | from | to |
|---------------------|---------------------------------------|------|-----|
| Letter McNeill Inc. | | | |
| Ret 2 | | | |
| Sauril, Miss | Clay | 0 | 9 |
| (mailing address) | Sand | 9 | 26 |
| | Sandy Clay | 26 | 35 |
| | Blue Clay | 35 | 55 |
| | Clay + Sand + Shale | 55 | 81 |
| | Sand (Blue) | 81 | 113 |

WELL LOCATION:

sec. 1 T. 9 N R. 11 E
 1 miles West Sandusville
 (distance) (direction) (nearest town)

WELL PURPOSE:

office shop
 (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 4
- (2) total depth (feet) 113
- (3) static water level (feet) 70 below top of ground.
- (4) casing Galuchon 93 (material) (depth)
- (size) if telescope see back.
- (5) screen 30 93 (length) (depth to top)
- 4 in Solid S.S. (size) (material)
- (6) pump 5 85 (HP) (yield gpm)
- 220V S.P. (type power)
- (7) electric log NO (yes or no)
- (organization running log)
- (8) how well bottom plugged B.W.V

CODED

JUL 22 1970

DRILLERS REMARKS: top 10 ft of screen 00% clogged
 10 ft. 0.00 Ret Pump
 On 103 ft 2 in pipe in screen

MISS. BD. OF
 WATER COMM.