

JONES  
C101 A+B  
9-18-70

2 - Water Samples  
1 - hole + electric log  
MISSISSIPPI  
BOARD OF WATER COMMISSIONERS  
416 North State Street  
Jackson, Mississippi 39201  
Elog 202

**CODED**  
Elog 202

WATER WELL DRILLERS LOG

9/18 1970 C.P. Clark Jones  
date well completed firm name county well located

LANDOWNER: Sharon Water Works Inc.  
(mailing address)

WELL LOCATION:  
sec. 34 T. 10 N. R. 11 E  
5 miles North of Laurel  
(distance) (direction) (nearest town)

WELL PURPOSE: Main System  
(home, irrigation, municipal, industrial)  
Flat Hall

WELL COMPLETION DATA:  
(1) diameter (inches) 2  
(2) total depth (feet) 267  
(3) static water level (feet) 115 below top of ground. on 176 ft test  
109 on 24 ft test  
(4) casing 171 and 242  
(material) (depth)  
(size) if telescope see back.  
(5) screen 5 171+242  
(length) (depth to top)  
2 Solid S.S. 008  
(size) (material)  
(6) pump 1 1/2 5 and 8  
(HP) (yield gpm)  
220V S.P.  
(type power)  
(7) electric log Yes  
(yes or no)  
Miss. Geo. Survey  
(organization running log)  
(8) how well bottom plugged BWV

description of formations encountered	from to	
Red Clay	0	15
Sand + pea gravel	15	22
Course Sand	22	70
Hard sticky blue clay	70	149
Good Sand (Med)	149	170
Course sand	170	176
Soft Clay	176	178
Sand & clay streaks (50-50)	178	190
Clay shell breaks	190	204
Light Sand & clay streaks	204	212
Fine Blue Sand	212	219
Blue Sand (medium)	219	247
Clay, shells + Hard streaks	247	264
Blocks	264	267

**CODED**

OCT 23 1970

MISS. BD. OF  
WATER COMM.

DRILLERS REMARKS: Set surface casing to 15 ft to seal off top sand & gravel + obtain full circulation 4 in pipe 1.0