MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	Jones
WELL NUMBER	D 2030
CODED	
DATE WELL COMPLETED	8-21-98
PERMIT NUMBER	
NAME OF DRILLING FIRM	Roy V. West

NAME & MAILING ADDRESS OF LANDOWNER
C.W. Pearson
Radio Road
Laurel MS

WELL LOCATION — SEC 29 TOWNSHIP 9 N/S RANGE 10 E/W

DISTANCE 6 Miles DIRECTION E of NEAREST TOWN Laurel

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 2

Pump Capacity (GPM)	No. of Stages	Setting Depth
12		120 FT.

PUMP TEST

Well yielded _____ GPM with

a drawdown of _____ ft.

after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
140	4	130
Type of Casing	**Hole Depth**	**Depth to Static Water Level**
PVC	140	75

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4	10	.010
Screen Type		**Depth to Bottom - Feet**
PVC		140

Driller's Remarks
Mint Springs Sand
Good water quality

Top of Lap Pipe or Reduction in Casing
FEET — IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
SANDY CLAY	0	8			
SAND	8	24			
CLAY + SANDSTEKS	24	45			
CLAY	45	102			
Limestone + CLAY	102	130			
Limestone + sandstone	130	140			
			IF MORE SPACE IS NEEDED, USE BACK		