

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED JONES	
WELL NUMBER D2036	CODED
DATE WELL COMPLETED 10/6/99	

PERMIT NUMBER
NAME OF DRILLING FIRM THOMPSON BROS.

NAME & MAILING ADDRESS OF LANDOWNER THOMAS BATY			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	35	9	N 10 E
DISTANCE	DIRECTION	NEAREST TOWN	
8 Miles	E	of LAUREL	
OTHER LANDMARK			
WELL PURPOSE Home, Irrigation, Municipal, industrial, Fish Pond, etc. HOME			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet, NONE , Flowing Well, Other (Describe)		
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe)		
Pump Capacity (GPM)	No. of Stages	Setting Depth
		FT.
PUMP TEST		
Well yielded 60 GPM with a drawdown of 15 ft. AIR LIFT after 15 hours of pumping		

WELL DATA		
Well Depth 96'	Casing Diameter (In.) 4"	Casing Length (Ft.) 86'
Type of Casing PVC	Hole Depth 96	Depth to Static Water Level 80

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)	
Name of Organization Running Log	

TYPE OF COMPLETION: (Circle One or More): <input checked="" type="checkbox"/> Gravel Packed, <input type="checkbox"/> Underreamed, <input type="checkbox"/> Telescoped, <input type="checkbox"/> Natural Development, <input type="checkbox"/> Open Hole, <input type="checkbox"/> Other			
WELL GROUTED TO A DEPTH OF 12 FEET Type Grout (circle one): Cement, Bentonite, or Mix			

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA		
Diameter - Inches 4	Length - Feet 10	Slot Size - Inches .010
Screen Type PVC	Depth to Bottom - Feet 96	

Driller's Remarks
**NO PUMP INSTALLED
IN THIS WELL
(VERY GOOD WELL)**

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMAT
RED CLAY	0	33	
BROKEN FINE SAND			
CLAY	33	79	
GOOD WHITE SAND	79	96	

RECEIVED

DEC 10 1999

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK